

Table of Contents

1 Introduction

1.1 Scope	1-1
1.2 Qualification Criteria	1-1
1.3 Hygroscopic Dust	1-1
1.4 Failure Mechanisms	1-1
1.5 Dust Accumulation Rates	1-3
1.6 Dust Qualification Tests Background	1-4
1.7 Requirements Terminology	1-5
1.8 Requirement Labeling Conventions	1-5
1.8.1 Numbering of Requirement and Related Objects	1-5
1.8.2 Requirement, Conditional Requirement, and Objective Identification	1-6

2 Test Description

2.1 General	2-1
2.2 Family Designs and Test Samples	2-1
2.3 Control Coupon	2-1
2.4 Surface Film	2-2
2.5 Test Environment	2-3
2.6 Functional Test	2-3
2.7 Analysis of Test Results	2-4
2.8 Test Sequence Summary	2-4
2.9 Test Report	2-4

3 Conclusion

Appendix A: Number of Years Necessary to Accumulate Enough Dust Particles to Assure Connectivity

Appendix B: Deposition Techniques

Appendix C: Effect of Hygroscopic Salts on Surface Insulation Resistance and RHt Determination Example

Appendix D: Example of Environment Control System

Appendix E: Example of a Test Report

Appendix F: References

Appendix G: Acronyms

Requirement-Object Index

List of Figures

Figure 1-1	(a) Voltage Breakdown Through Dust Film/Solder Mask Defects for an Integrated Circuit on a PWA, (b) Pin-to-Pin Leakage Current Path Along Dust Film	1-2
Figure 1-2	Surface Insulation Resistance Loss Versus RH Measured Under 5 Volts Bias on a Telecommunication PWA Contaminated by Airborne Hygroscopic Dust	1-3
Figure 2-1	Test Sequence Summary	2-5
Figure B-1	Sketch of a Hygroscopic Salt Mist Deposition System	B-1
Figure C-1	Surface Insulation Resistance Loss Versus RH Measured on an IPC Coupon After Deposition of (a) Sodium Sulfide 0.1 M, (b) Potassium Carbonate Sesquihydrate 0.1 M, and (c) Calcium Chloride Dihydrate (0.1 M)	C-1
Figure C-2	Threshold RH for Surface Insulation Resistance Loss Versus RH Measured on a IPC Coupon After Deposition of Sodium Sulfide (0.1 M)	C-2
Figure C-3	Dependence of the Surface Insulation Resistance at 90% RH With the Amount of Sodium Sulfide Deposited	C-3
Figure D-1	Box Used to Control the Environment Around a PWA Connected to a System via an Extension Card	D-1

List of Tables

Table A-1	Typical Average Outdoor Mean Concentration of Fine Particles in $\mu\text{g}/\text{m}^3$	A-3
Table A-2	Typical Average Indoor Mean Concentration of Fine Particles in $\mu\text{g}/\text{m}^3$	A-3
Table D-1	Equilibrium RH at 24°C for Different Saturated Saline Solutions . .	D-2

